



Schedule 1: Compliance with Section 37 Application Requirements

Kempston West End Overhead Line

| Requirement | Applicant's Compliance |
|---|---|
| The company's reference number; | 12351905 |
| The name of the scheme/line; | Kempston West End Overhead Line (associated with the Snakes Meadow Solar Farm Project) |
| The Location – relevant planning authority and parish; | <p>Land off West End Road, Kempston West End, Bedford Bedfordshire MK43 8RZ</p> <p>Planning Authority: Bedford Borough Council Parish Council: Kempston Rural Parish Council</p> |
| Confirmation of compliance with the Electrical Safety, Quality and Continuity Regulations 2002; | The proposed development will comply with the Electrical Safety, Quality and Continuity Regulations 2002. |
| The specification and length of the proposed route; | <p>Specification:</p> <p>The application relates to proposed new overhead electric line ('OHL') works in connection with the proposed Snakes Meadow Solar Farm. The point of connection compound will require an approximately 15 metre section of 132kV OHL to be installed from its busbars in order to connect it (and the Proposed Solar Farm) to an existing pylon tower located adjacent to West End Road, Kempston West End.</p> <p>The easting and northing of the proposed OHL is X: 499276.798 and Y: 247591.499.</p> <p>The location and alignment of the proposed OHL is shown on the submitted Site Layout Plan (Ref. RNC001-PL-03_rev07).</p> <p>For more information, please refer to the Application Covering Letter.</p> |
| The Voltage of the Line | 132kV |

| | |
|--|---|
| If the relevant planning authority/other consultees have requested conditions to be included; | Not at this stage. |
| Whether all permissions have been obtained from landowners and/or occupiers for the land along the proposed route. | Renewable Connections Developments Limited has secured the requisite rights through agreements with the relevant landowner. |